

Gull Lake Sewer + Water Authority

Pole Barn 2017 – 2018

Addendum #3:

December 11, 2017

1. Clarification of Work Bench Construction: Allowance \$500.00 dollars: The stated allowance for the work bench construction shall also include the purchase of materials for the work bench.
2. Electrical service: As noted in Addendum #2, electrical service within the proposed Pole Barn is to be 200 Amp using the existing available 3" conduit from the east side of the main office that extends underground approximately 120 feet to the site.

For feed to the new Pole Barn, electrical contractors shall install parallel 200 Amp electrical service from off of the existing transfer switch (load side of transfer switch).

End of Addendum #3: